



# DVGW certificate of conformity hygiene

## DVGW-Konformitätsbestätigung Hygiene

**HW-0834DP0278**  
Registration Number  
Registriernummer

**Confirmation of Conformity** based on type testing (simplified process)  
*Konformitätsbestätigung* auf Basis einer Typrüfung (vereinfachtes Verfahren)

**Owner of certificate**  
*Zertifikatinhaber*

[Redacted]

**Manufacturer**  
*Hersteller*

[Redacted]

**Product Category**  
*Produktart*

Hygienic suitability based on a type testing: Components from elastomers, product group P3 (0834)

**Product description**  
*Produktbezeichnung*

Elastomer components for drinking water installations

**Material/Model**  
*Werkstoff/Modell*

Elastomer, Fibre / Fibre Gasket

**Test reports**  
*Prüfberichte*

Certification report: from 24.07.2024 (ZGW)  
UBA Guideline/BWGL: 5-0064/24 T01 from 05.03.2024 (TZW)  
Hygienic testing: 5-1075/22 T01 from 28.03.2023 (TZW)

**Test basis**  
*Prüfgrundlagen*

DVGW CERT ZP 0800 (20.04.2022)  
UBA KTW-BWGL (07.03.2022)  
DIN EN 16421 (01.05.2015)

**Date of Expiry / File No.** 24.07.2029 / 24-0333-WHE  
*Ablaufdatum / Aktenzeichen*

This is to confirm that, based on the DVGW CERT ZP 0800 certification programme, the product information made available, including the recipe specifications and the above mentioned assessment report, the above mentioned product/component meets the requirements of, and complies with, the assessment basis/guideline of the German Federal Environmental Agency mentioned under Test Specifications for the temperature range listed on the reverse. (The requirements for product groups with lower conversion factors (Fc) are met as well.)

31.07.2024 Pek A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



<b>Type Typ</b>	<b>Technical Data Technische Daten</b>	<b>Remarks Bemerkungen</b>
Fibre Gasket	requirements of KTW-BWGL 5.6.3 c): M1 Application: Drinking water installation Production method: Compression moulding Temperature range: Hot water, up to 85 °C Material type: BELPA CSA-50	Color: green

The assessment reports listed under Test Reports are an integral part of the confirmation of conformity. The confirmation of conformity is valid from date of issue and remains valid as long as the requirements listed under "Notes" are met.

### Notes

The confirmation of conformity was issued on the condition that the raw materials used to manufacture the product or rather their composition and/or components, including the latter's manufacturer and supplier chain have been disclosed in full and no other substances are contained in the product. The validity of this document expires in the event of modifications to the composition of the product or to the processing conditions that were not coordinated with the certification body and in the event of non-compliance with the conformity requirements as well as in the event of termination of the 1+ system monitoring programme of certification body and manufacturer.

The results of our tests and the assessments apply to the test items examined and the statutory regulations valid at the time of testing. Without our express written approval, this document may only be published or reproduced in complete and unaltered form.

This confirmation of conformity is only valid in conjunction with a corresponding entry in the Internet directory of DVGW CERT GmbH (<http://www.dvgw-cert.com>). The confirmation of conformity remains the property of DVGW CERT GmbH and must be returned to DVGW CERT GmbH upon request.